

ENVIRONMENTAL PARAMETERS FOR ANIMAL HOUSING AREAS

<u>Bldg. 115</u> <u>Room#</u>	<u>Temperature</u> <u>Min. Opt. Max.</u>	<u>Humidity</u> <u>Min. Opt. Max.</u>	<u>Species</u>
043	71° - 74° - 79°	30% - 45% - 55% - 70%	Animal Transfer (Rodents)
044 (A-C)	71° - 74° - 79°	30% - 45% - 55% - 70%	Behavioral Suite (Rodents)
045	61° - 72° - 81°	30% - 45% - 55% - 70%	Lg/ Quarantine (Swine/Canine/NHP)
046	71° - 74° - 79°	30% - 45% - 55% - 70%	Sm. Quarantine (Rodents)
047	71° - 74° - 79°	30% - 45% - 55% - 70%	Animal Receiving (Rodents)
048	71° - 74° - 79°	30% - 45% - 55% - 70%	NCA Holding 1 (Rodents)
051	71° - 74° - 79°	30% - 45% - 55% - 70%	NCA Holding 2 (Rodents)
052	71° - 74° - 79°	30% - 45% - 55% - 70%	Decon Room (Rodents)
075 (A-F)	71° - 74° - 79°	30% - 45% - 55% - 70%	ABSL2 (Rodents)
079	64° - 72° - 84°	30% - 45% - 55% - 70%	NHP Holding 3
080	64° - 72° - 84°	30% - 45% - 55% - 70%	NHP Holding 2
081	64° - 72° - 84°	30% - 45% - 55% - 70%	NHP Holding 1
082	61° - 72° - 81°	30% - 45% - 55% - 70%	Swine
083	61° - 72° - 81°	30% - 45% - 55% - 70%	Swine
084 (A-D)	61° - 65° - 72°	30% - 45% - 55% - 70%	Holding Cubicle (Rabbit)
085	61° - 65° - 72°	30% - 45% - 55% - 70%	Gen. Conv. Interchangeable (Rabbit)
086	71° - 74° - 79°	30% - 45% - 55% - 70%	Gen. Conv. Room 2 (Rodents)
087	71° - 74° - 79°	30% - 45% - 55% - 70%	Gen. Conv. Room 1 (Rodents)
088	71° - 74° - 79°	30% - 45% - 55% - 70%	Barrier Room 2 (Rodents)
089	71° - 74° - 79°	30% - 45% - 55% - 70%	Barrier Room 1 (Rodents)
 <u>Bldg. 112</u>			
<u>Room#</u>			
222	71° - 74° - 79°	30% - 45% - 55% - 70%	Rodents
322	71° - 74° - 79°	30% - 45% - 55% - 70%	Rodents
310	71° - 74° - 79°	30% - 45% - 55% - 70%	Rodents
312	71° - 74° - 79°	30% - 45% - 55% - 70%	Rodents